

~~DUPLICATE~~

METEOROLOGICAL OFFICE

London Road, Bracknoll, Berkshire.

AT BIRMINGHAM AIRPORT 1960-74

BY H. J. BAKER AND JOYCE LAING

Introduction

Hourly observations of dry-bulb and wet-bulb temperatures were made at Birmingham Airport (Shedden) NGR SP176032 during the 15 years 1960-74. The thermometers were exposed in the standard louvered screen 4 feet (1.25 metres approximately) above short grass. An analysis has been made by computer of these observations to give hourly and annual tables showing the percentage frequency of combinations of dry- and wet-bulb readings in ranges of one degree Celsius. Tables are also given showing the frequency of dry-bulb and wet-bulb temperatures separately.

CLIMATOLOGICAL MEMORANDUM 80

Tables 1 to 13 contain for each month, and for the year, the distribution of combined dry-bulb and wet-bulb temperature. The ranges of dry-bulb temperature are shown down the left hand side; the ranges of wet-bulb temperature, across the page, are for the sake of brevity given as T (the dry-bulb temperature range for the row) $T-1$ degC, $T-2$ degC etc. Thus if T is 0.1 to 1.0 then $T-1$ is -0.9 to 0.0 and so on.

For any given range of dry-bulb temperature and associated wet-bulb temperature two values are given. The first value is the percentage frequency of hours when the dry-bulb temperature is within the range and the wet-bulb temperature is greater than, or equal to, the lower value in the range. The second value is the percentage frequency of hours when the dry-bulb temperature is within the range and the wet-bulb temperature is greater than, or equal to, the lower value in the range.

PERCENTAGE FREQUENCY OF HOURLY VALUES OF
DRY - BULB AND WET - BULB TEMPERATURES AT

BIRMINGHAM AIRPORT 1960 - 74.

Example: In Table 1 (January) the percentage frequency of hours when the dry-bulb temperature is within the range 5.1 to 6.0 deg C (column T-2) is 1.45. The cumulative value in this 'box', 20.3 indicates that a dry-bulb temperature of 7.1 deg C or more and an associated wet-bulb temperature of 5.1 deg C or more occurred on 20.3 per cent of the hours. This value is derived by the sum of the upper figures in each box below and to the left of a diagonal through the box commencing to the bottom right of the table, thus:

H.J. Baker and Joyce Laing

2.47			0.34	0.01
1.13	2.74	1.33	0.24	0.03
0.01	2.02	0.81	0.26	0.04
0.32	1.60	0.39	0.16	0.04
0.10	0.63	0.26	0.06	0.01
	0.03	0.19	0.03	0.01

Slight discrepancies may occur in the last place of six decimal figures in the percentage frequencies were calculated. The printed values obtained by simple addition of the figures in the table.



3 8078 0007 0373 8

ORGS UKMO C Duplicate

National Meteorological Library
FitzRoy Road, Exeter, Devon. EX1 3PB

Climatological Services (Met. O. 3)

July 1976

CLIMATOLOGICAL MEMORANDUM NO. 80

PERCENTAGE FREQUENCY OF HOURLY VALUES OF DRY-BULB AND WET-BULB TEMPERATURES

AT BIRMINGHAM AIRPORT 1960-74

BY H J BAKER AND JOYCE LAING

Introduction

Hourly observations of dry-bulb and wet-bulb temperature were made at Birmingham Airport (Elmdon) NGR SP/176839 during the 15 years 1960-74. The thermometers were exposed in the standard louvered screen 4 feet (1.25 metres approximately) above short grass. An analysis has been made by computer of these observations to give monthly and annual tables showing the percentage frequency of combinations of dry- and wet-bulb readings in ranges of one degree Celsius. Tables are also given showing the frequency of dry-bulb and wet-bulb temperatures separately.

Explanation of the tables

Tables 1 to 13 contain for each month, and for the year, the distribution of combined dry-bulb and wet-bulb temperature. The ranges of dry-bulb temperature are shown down the left hand side: the ranges of wet-bulb temperature, across the page, are for the sake of brevity given as T (the dry-bulb temperature range for the row) $T-1$ degC, $T-2$ degC etc. Thus if T is 0.1 to 1.0 then $T-1$ is -0.9 to 0.0 and so on.

For any given range of dry-bulb temperature and associated wet-bulb temperature two values are given. The upper figure is the percentage frequency of occurrence within the given range calculated to two places of decimals; the lower figure is the cumulative percentage frequency of occurrence of dry-bulb temperature and associated wet-bulb temperature greater than, or equal to, the lower values in the appropriate range as indicated, calculated to one place of decimals. Entries of 0.0+ indicate values of less than .05 per cent but greater than zero.

Example. In Table 1 for January, the percentage frequency of the number of hours with dry-bulb temperature within the range 7.1 to 8.0 deg C and the associated wet-bulb temperature within the range 5.1 to 6.0 deg C (column $T-2$) is 1.48. The cumulative value in this 'box', 20.3, indicates that a dry-bulb temperature of 7.1 deg C or more and an associated wet-bulb temperature of 5.1 deg C or more occurred on 20.3 per cent of the hours. This value is derived from the sum of the upper figures in each box below and to the left of a diagonal through the box concerned to the bottom right of the table, thus:

2.47	3.09	1.48	0.34	0.01
1.13	2.74	1.33	0.24	0.03
0.91	2.02	0.81	0.28	0.04
0.32	1.50	0.39	0.18	0.04
0.10	0.63	0.29	0.06	0.01
	0.03	0.19	0.03	0.01

Slight discrepancies may occur in the last place of decimals due to the rounding off of figures when the percentage frequencies were calculated; the printed cumulative figures are correct rather than those obtained by simple addition of the figures in the table.

Table 14 gives the frequency of dry-bulb temperatures alone and table 15 gives the frequency of wet-bulb temperatures alone. The annual percentage frequencies have been worked from all the data and are not a direct mean of the monthly figures.

Average of accumulated temperature

Accumulated temperatures are the integrated excess or deficit from a stated base temperature, and are expressed as degree-days or degree-hours. From data given in table 14 the degree-hours can be calculated using the following method.

The average number of degree-hours in any month above a base temperature (b °C) is given by the sum of the products obtained by multiplying the entries for that month which refer to temperatures greater than b °C (ie those values lying beneath the entry referring to the range of temperature whose upper limit is b) by $(1/2) \times (N/100)$, $(3/2) \times (N/100)$, $(5/2) \times (N/100)$ etc. respectively, where N is the number of hours in the month. This assumes, in effect, that the entries in the ranges $(b + 0.1)$ to $(b + 1)$, $(b + 1.1)$ to $(b + 2)$ etc. are concentrated at mid-point of the range $(b + 0.5)$, $(b + 1.5)$ etc.

Example. In May (number of hours 744) the average number of degree-hours above 15°C is (from table 14):

$$4.1 \times (1/2) \times (744/100) = 15.3$$

$$2.9 \times (3/2) \times (744/100) = 32.4$$

$$2.3 \times (5/2) \times (744/100) = 42.8$$

$$1.7 \times (7/2) \times (744/100) = 44.3$$

$$1.2 \times (9/2) \times (744/100) = 40.2$$

$$0.7 \times (11/2) \times (744/100) = 28.6$$

$$0.4 \times (13/2) \times (744/100) = 19.3$$

$$0.3 \times (15/2) \times (744/100) = 16.7$$

$$0.2 \times (17/2) \times (744/100) = 12.6$$

$$0 \times (19/2) \times (744/100) = 0$$

$$252.2$$

To obtain the number of degree-hours below base b °C the procedure is the same except that the percentages used are those for the temperature ranges below and including the range of temperature which has b °C as its upper limit.

This memorandum replaces No. 17, now out of print; similar data for other stations in the United Kingdom will be published in due course.

0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DEG-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-12.5 to -12.0	0.05 100.0								
-14.5 to -14.0	0.08 100.0								
-17.5 to -17.0	0.04 99.9	0.01 99.9							
-15.5 to -15.0	0.08 99.8	0.01 99.9							
-11.5 to -11.0	0.07 99.8	0.01 99.8							
-10.0 to -10.0	0.55 99.7								
-9.0 to -9.0	0.54 99.4	0.05 99.5							
-8.5 to -8.0	0.77 99.1	0.77 99.5							
-7.5 to -7.0	0.30 98.8	0.66 98.8							
-6.5 to -6.0	0.56 98.3	0.17 98.5							
-5.5 to -5.0	0.76 97.6	0.18 97.8							
-4.5 to -4.0	0.84 96.3	0.37 96.3							
-3.5 to -3.0	0.91 94.9	0.62 95.8	0.01 99.9						
-2.5 to -2.0	1.57 93.0	0.66 94.0	0.05 94.1						
-1.5 to -1.0	5.35 87.8	1.63 91.7	0.15 91.9						
0.0 to 0.0	7.68 84.7	5.37 87.5	0.37 87.8						

Table 1 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

JANUARY 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-15.9 to -15.0	0.02 100.0								
-14.9 to -14.0	0.08 100.0								
-13.9 to -13.0	0.04 99.9	0.01 99.9							
-12.9 to -12.0	0.08 99.8	0.01 99.9							
-11.9 to -11.0	0.07 99.8	0.01 99.8							
-10.9 to -10.0	0.22 99.7								
-9.9 to -9.0	0.24 99.4	0.02 99.5							
-8.9 to -8.0	0.33 99.1	0.05 99.2							
-7.9 to -7.0	0.30 98.8	0.06 98.8							
-6.9 to -6.0	0.56 98.3	0.13 98.5							
-5.9 to -5.0	0.76 97.6	0.18 97.8							
-4.9 to -4.0	0.84 95.5	0.37 95.8							
-3.9 to -3.0	0.91 94.9	0.65 95.6	0.01 95.6						
-2.9 to -2.0	1.27 93.0	0.86 94.0	0.05 94.1						
-1.9 to -1.0	2.32 89.8	1.62 91.7	0.12 91.9						
-0.9 to 0.0	3.48 84.7	2.37 87.5	0.33 87.8						

Table 1 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd)
JANUARY 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
0.1 to 1.0	3.99 76.7	3.80 81.2	0.37 81.6	0.01 81.6			10.0 0.001	0.11- of 0.11-	
1.1 to 2.0	3.52 68.5	3.60 72.7	0.75 73.4	0.01 73.5			50.0 0.001	0.01- of 0.01-	
2.1 to 3.0	3.95 59.8	4.25 65.0	0.56 65.5	0.03 65.6			20.0 0.001	0.0- of 0.0-	
3.1 to 4.0	3.85 49.8	4.44 55.9	0.88 56.8		50.0 0.00	20.0 0.00		0.8- of 0.8-	
4.1 to 5.0	3.41 39.8	4.57 45.9	1.34 47.6	0.06 47.6	20.0 0.00	25.0 0.00		0.5- of 0.5-	
5.1 to 6.0	3.07 29.6	4.61 36.4	1.19 38.0	0.23 38.2	20.0 0.00	21.0 0.00		0.0- of 0.0-	
6.1 to 7.0	2.72 21.3	3.54 26.6	1.78 28.7	0.39 29.1	0.04 29.1	21.0 0.00	24.0 0.00	0.2- of 0.2-	
7.1 to 8.0	2.47 13.8	3.09 18.5	1.48 20.3	0.34 20.7	0.01 20.7	21.0 0.00	23.0 0.00	0.4- of 0.4-	
8.1 to 9.0	1.13 7.6	2.74 11.3	1.33 13.0	0.24 13.2	0.03 13.3	20.0 0.00	20.1 0.00	0.2- of 0.2-	
9.1 to 10.0	0.91 4.0	2.02 6.5	0.81 7.5	0.28 7.8	0.04 7.8	20.0 0.00	20.1 0.00	0.5- of 0.5-	
10.1 to 11.0	0.32 1.3	1.50 3.1	0.39 3.5	0.18 3.7	0.04 3.8	20.0 0.00	21.5 0.00	0.1- of 0.1-	
11.1 to 12.0	0.10 0.1	0.63 0.9	0.29 1.3	0.06 1.3	0.01 1.3	20.0 0.00	20.5 0.00	0.0- of 0.0-	
12.1 to 13.0		0.03 0.0	0.19 0.2	0.03 0.2	0.01 0.3	20.0 0.00	20.5 0.00	0.1- of 0.1-	

Table 2 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
FEBRUARY 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-11.9 to -11.0	0.01 100.0								
-10.9 to -10.0	0.02 100.0								
-9.9 to -9.0	0.03 100.0								
-8.9 to -8.0	0.03 99.9	0.02 99.9							
-7.9 to -7.0	0.25 99.8	0.05 99.9							
-6.9 to -6.0	0.43 99.5	0.05 99.6							
-5.9 to -5.0	0.42 99.0	0.12 99.1							
-4.9 to -4.0	0.67 98.4	0.18 98.6							
-3.9 to -3.0	1.03 97.2	0.50 97.7	0.01 97.7						
-2.9 to -2.0	1.86 95.0	0.99 96.1	0.07 96.2						
-1.9 to -1.0	2.47 91.0	1.98 93.2	0.12 93.3						
-0.9 to 0.0	3.36 84.7	2.88 88.5	0.21 88.7						
0.1 to 1.0	4.24 75.2	4.42 81.3	0.85 82.3	0.01 82.3					
1.1 to 2.0	3.12 64.9	4.51 70.9	1.46 72.7	0.03 72.7					
2.1 to 3.0	2.65 55.5	4.16 61.8	1.27 63.3	0.26 63.6	0.04 63.6				
3.1 to 4.0	3.42 46.2	4.18 52.9	1.59 55.0	0.25 55.2	0.02 55.3				
4.1 to 5.0	2.78 35.3	5.10 42.8	1.96 45.3	0.50 45.8	0.0 45.8				

Table 2 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
 (contd)
 FEBRUARY 1960-74
 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7 (DEG)	T-8
5.1 to 6.0	1.72 24.8	4.65 32.5	1.93 34.9	0.47 35.4	0.04 35.5		0.00	0.01- of 0.01-	
6.1 to 7.0	1.69 17.5	3.37 23.1	2.24 26.1	0.47 26.7	0.01 26.7		0.00	0.01- of 0.01-	
7.1 to 8.0	1.24 11.5	2.70 15.8	1.50 18.0	0.73 18.8	0.06 18.9		0.00	0.01- of 0.01-	
8.1 to 9.0	0.62 6.6	2.25 10.3	1.21 11.9	0.65 12.6	0.09 12.6		0.00	0.01- of 0.01-	
9.1 to 10.0	0.43 2.9	1.87 6.0	1.12 7.4	0.28 7.8	0.06 7.8		0.00	0.01- of 0.01-	
10.1 to 11.0	0.06 0.8	1.17 2.5	0.91 3.7	0.29 4.0	0.08 4.1		0.00	0.01- of 0.01-	
11.1 to 12.0	0.02 0.2	0.33 0.7	0.44 1.3	0.22 1.5	0.03 1.6	0.01 1.6	0.00	0.01- of 0.01-	
12.1 to 13.0		0.13 0.2	0.12 0.3	0.12 0.5	0.03 0.5		0.00	0.01- of 0.01-	
13.1 to 14.0		0.03 0.0	0.01 0.1	0.02 0.1	0.02 0.1		0.00	0.01- of 0.01-	
14.1 to 15.0			0.02 0.0	0.02 0.0			0.00	0.01- of 0.01-	

Table 3 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

MARCH

1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-10.9 to -10.0	0.04 100.0								
-9.9 to -9.0	0.04 100.0								
-8.9 to -8.0	0.04 99.9								
-7.9 to -7.0	0.13 99.8	0.03 99.9							
-6.9 to -6.0	0.35 99.7	0.03 99.7							
-5.9 to -5.0	0.39 99.3	0.03 99.3							
-4.9 to -4.0	0.35 98.8	0.14 98.9							
-3.9 to -3.0	0.47 98.3	0.17 98.4							
-2.9 to -2.0	0.91 97.3	0.44 97.8							
-1.9 to -1.0	1.20 95.3	0.96 96.4	0.04 96.4						
-0.9 to 0.0	1.88 91.8	1.81 94.1	0.14 94.2						
0.1 to 1.0	2.28 85.7	2.85 89.9	0.39 90.4						
1.1 to 2.0	2.89 78.5	3.17 83.4	1.08 84.8	0.08 84.9					
2.1 to 3.0	2.86 69.3	3.99 75.6	1.28 77.3	0.24 77.7					
3.1 to 4.0	2.82 59.3	4.35 66.5	1.39 68.7	0.33 69.2	0.09 69.3				
4.1 to 5.0	2.61 48.1	4.20 56.5	1.94 59.3	0.58 60.2	0.13 60.3				
5.1 to 6.0	1.94 36.4	4.00 45.4	2.46 49.7	0.63 50.5	0.28 50.8	0.01 50.8			
6.1 to 7.0	2.11 26.3	3.35 34.5	2.58 39.5	1.13 41.3	0.23 41.5	0.01 41.5			

Table 3 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) MARCH 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
T (DEG C)									
7.1 TO 8.0	1.51 17.0	3.10 24.2	2.28 28.8	1.60 31.3	0.55 31.9				
8.1 TO 9.0	0.92 10.1	2.36 15.5	2.35 19.6	1.56 21.9	0.67 22.8	0.10 22.9			
9.1 TO 10.0	0.62 5.2	1.83 9.2	1.65 12.2	1.08 13.9	0.66 14.7	0.16 14.9			
10.1 TO 11.0	0.12 2.1	1.05 4.6	0.92 6.7	0.78 8.1	0.50 8.8	0.12 8.9	0.02 8.9		
11.1 TO 12.0	0.0 0.9	0.37 2.0	0.65 3.4	0.67 4.7	0.40 5.3	0.13 5.4	0.03 5.4	0.01 5.4	
12.1 TO 13.0	0.0 0.3	0.05 0.9	0.25 1.6	0.34 2.4	0.28 3.0	0.15 3.2	0.0 3.2	0.01 3.2	
13.1 TO 14.0		0.02 0.3	0.11 0.9	0.21 1.3	0.22 1.7	0.17 2.0	0.02 2.1	0.01 2.1	
14.1 TO 15.0			0.03 0.3	0.13 0.8	0.10 1.0	0.07 1.2	0.08 1.3	0.04 1.4	
15.1 TO 16.0			0.02 0.0	0.04 0.2	0.09 0.6	0.11 0.7	0.05 0.9	0.04 0.9	
16.1 TO 17.0					0.04 0.2	0.11 0.5	0.02 0.5	0.04 0.6	0.01 0.6
17.1 TO 18.0						0.02 0.1	0.06 0.3	0.0 0.3	0.03 0.4
18.1 TO 19.0							0.04 0.1	0.05 0.2	0.01 0.3
19.1 TO 20.0	T-9 0.01 0.2	T-10						0.05 0.1	0.02 0.1
20.1 TO 21.0	0.03 0.1								0.02 0.0
21.1 TO 22.0		0.02 0.0						0.01 0.0	

Table 4 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
APRIL 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

T (DEG C)		T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-6.9 TO	-6.0	0.02 100.0								
-5.9 TO	-5.0	0.02 100.0	0.01 100.0							
-4.9 TO	-4.0	0.09 99.9	0.01 100.0							
-3.9 TO	-3.0	0.14 99.8	0.06 99.9							
-2.9 TO	-2.0	0.25 99.5	0.19 99.7							
-1.9 TO	-1.0	0.37 99.0	0.24 99.2	0.01 99.2						
-0.9 TO	0.0	0.76 98.1	0.38 98.6	0.02 98.6						
0.1 TO	1.0	0.92 96.4	0.69 97.3	0.08 97.4						
1.1 TO	2.0	1.45 93.6	1.23 95.5	0.20 95.7	0.04 95.7					
2.1 TO	3.0	1.58 88.8	2.20 92.2	0.41 92.8	0.04 92.8					
3.1 TO	4.0	1.60 82.0	2.93 87.2	0.74 88.4	0.17 88.6					
4.1 TO	5.0	2.54 72.4	3.95 80.4	1.36 82.7	0.31 83.1	0.02 83.2				
5.1 TO	6.0	2.17 60.8	4.14 69.9	2.24 73.9	0.59 74.9	0.12 75.0				
6.1 TO	7.0	2.13 49.5	3.69 58.7	2.39 63.6	1.08 65.4	0.21 65.7				
7.1 TO	8.0	1.89 37.9	3.90 47.4	2.40 52.8	1.60 55.4	0.56 56.1	0.11 56.2			
8.1 TO	9.0	1.53 26.8	3.82 36.0	2.59 41.6	1.65 44.7	0.74 45.6	0.15 45.7			
9.1 TO	10.0	1.27 17.0	2.99 25.3	2.45 30.7	1.51 33.6	1.05 35.1	0.19 35.3	0.01 35.3		

Table 4 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) APRIL 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8	T-9
10.1 TO 11.0	0.68 8.7	2.30 15.8	1.79 21.0	1.59 23.9	1.09 25.4	0.36 25.8				
11.1 TO 12.0	0.31 3.8	1.28 8.1	1.66 12.8	1.58 16.2	0.97 17.6	0.32 18.0	0.04 18.0			
12.1 TO 13.0	0.08 1.3	0.53 3.4	0.94 6.5	1.44 9.6	1.12 11.4	0.32 11.8	0.03 11.8			
13.1 TO 14.0	0.01 0.5	0.19 1.2	0.49 2.8	0.94 4.9	0.96 6.6	0.50 7.3	0.06 7.4	0.01 7.4		
14.1 TO 15.0	0.0 0.1	0.06 0.4	0.22 1.0	0.51 2.1	0.47 3.3	0.49 4.0	0.19 4.2			
15.1 TO 16.0		0.02 0.1	0.10 0.4	0.09 0.7	0.29 1.4	0.46 2.0	0.14 2.2	0.01 2.3		
16.1 TO 17.0			0.03 0.1	0.06 0.3	0.03 0.5	0.21 0.9	0.18 1.1	0.03 1.1	0.02 1.1	
17.1 TO 18.1				0.01 0.1	0.07 0.2	0.05 0.4	0.08 0.5	0.05 0.6	0.02 0.6	
18.1 TO 19.1				0.01 0.0	0.03 0.1	0.01 0.1	0.07 0.3	0.05 0.3		
19.1 TO 20.1				0.01 0.0	0.01 0.0	0.01 0.0		0.07 0.1	0.01 0.1	
20.1 TO 21.0						0.02 0.0			0.02 0.0	
17.1 TO 18.0										0.01 0.6

Table 5 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) MAY 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-2.9 TO -2.0	0.03 100.0								
-1.9 TO -1.0	0.06 100.0	0.01 100.0							
-0.9 TO 0.0	0.16 99.9	0.04 99.9							
0.1 TO 1.0	0.26 99.6	0.13 99.7							
1.1 TO 2.0	0.25 99.0	0.25 99.3	0.02 99.3						
2.1 TO 3.0	0.34 98.4	0.29 98.8	0.01 98.8						
3.1 TO 4.0	0.68 97.3	0.57 98.1	0.04 98.2						
4.1 TO 5.0	0.62 95.2	0.89 96.6	0.18 96.8						
5.1 TO 6.0	1.19 91.3	1.77 94.6	0.38 95.1	0.03 95.2					
6.1 TO 7.0	1.51 84.7	2.63 90.1	1.02 91.6	0.13 91.8	0.02 91.8				
7.1 TO 8.0	2.42 74.7	3.70 83.2	1.59 86.0	0.28 86.4	0.02 86.5				
8.1 TO 9.0	2.66 61.2	4.93 72.3	2.35 77.0	0.68 78.3	0.12 78.4	0.04 78.5		0.01 78.5	
9.1 TO 10.0	2.18 46.2	4.30 58.5	2.70 64.7	1.41 67.1	0.36 67.7	0.04 67.7			
10.1 TO 11.0	1.78 32.4	3.68 44.1	3.06 52.0	1.77 55.5	0.64 56.5	0.15 56.7	0.01 56.7		
11.1 TO 12.0	1.19 21.6	2.58 30.6	2.85 38.6	2.32 43.5	0.91 45.2	0.30 45.6	0.04 45.6		
12.1 TO 13.0	0.46 13.5	1.93 20.5	2.04 26.8	2.24 32.0	1.32 34.6	0.59 35.3	0.07 35.4		
13.1 TO 14.0	0.26 7.4	1.16 13.1	1.49 18.1	1.74 22.4	1.61 25.3	0.91 26.6	0.15 26.8	0.02 26.8	

Table 5
(contd)

PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

MAY 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8	T-9	T-10
14.1 TO 15.0	0.05 3.4	0.65 7.2	1.29 11.7	1.29 15.2	1.25 17.8	0.87 19.1	0.25 19.4	0.02 19.5			
15.1 TO 16.0	0.0 1.6	0.20 3.4	0.62 6.5	0.98 9.7	1.01 11.9	0.91 13.2	0.31 13.7	0.09 13.8	0.02 13.8		
16.1 TO 17.0	0.0 0.5	0.05 1.6	0.26 3.2	0.59 5.7	0.82 7.9	0.72 9.1	0.30 9.5	0.11 9.6	0.03 9.7		
17.1 TO 18.0	0.0 0.1	0.02 0.5	0.15 1.6	0.37 2.9	0.56 4.8	0.76 6.1	0.38 6.6	0.12 6.8			
18.1 TO 19.0		0.0 0.1	0.05 0.5	0.22 1.4	0.26 2.3	0.62 3.7	0.44 4.3	0.07 4.4	0.04 4.4		
19.1 TO 20.0			0.01 0.1	0.10 0.4	0.21 1.1	0.33 1.8	0.42 2.5	0.09 2.7	0.02 2.7		
20.1 TO 21.0				0.03 0.1	0.12 0.3	0.19 0.8	0.19 1.1	0.18 1.5	0.04 1.6		
21.1 TO 22.0					0.02 0.1	0.06 0.2	0.08 0.5	0.12 0.6	0.08 0.8		
22.1 TO 23.0						0.01 0.1	0.02 0.1	0.16 0.3	0.0 0.3		
23.1 TO 24.0							0.05 0.1	0.03 0.1	0.06 0.2		
										T-9	T-10
21.1 TO 22.0								0.03 0.8	0.02 0.8		
22.1 TO 23.0								0.04 0.4	0.03 0.4		
23.1 TO 24.0								0.0 0.2	0.01 0.2		
24.1 TO 25.0								0.01 0.0	0.01 0.0		

Table 6 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
JUNE 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7
T (DEG C)								
-0.9 TO 0.0	0.01 100.0							
0.1 TO 1.0	0.01 100.0	0.02 100.0						
1.1 TO 2.0	0.02 100.0	0.01 100.0						
2.1 TO 3.0	0.11 99.9	0.02 99.9						
3.1 TO 4.0	0.31 99.7	0.10 99.8						
4.1 TO 5.0	0.33 99.2	0.17 99.4						
5.1 TO 6.0	0.54 98.5	0.30 98.9	0.02 98.9					
6.1 TO 7.0	0.81 97.2	0.55 98.0	0.05 98.0					
7.1 TO 8.0	0.70 94.7	1.20 96.4	0.18 96.6	0.01 96.6				
8.1 TO 9.0	0.99 90.1	2.13 94.0	0.40 94.5	0.06 94.5				
9.1 TO 10.0	1.27 82.3	3.08 89.1	0.93 90.8	0.10 91.0				
10.1 TO 11.0	1.38 71.1	3.47 81.0	1.66 84.7	0.52 85.6	0.03 85.6			
11.1 TO 12.0	1.80 58.8	3.72 69.7	2.43 76.2	1.11 78.2	0.20 78.5			
12.1 TO 13.0	1.84 44.7	3.89 57.0	2.71 64.2	1.80 68.2	0.56 69.2	0.07 69.3		
13.1 TO 14.0	1.10 31.1	3.44 42.9	2.69 51.2	1.72 55.8	1.18 58.0	0.29 58.4	0.01 58.4	
14.1 TO 15.0	0.50 19.6	2.59 30.0	2.65 38.3	1.83 44.0	1.40 46.8	0.76 47.9	0.07 48.0	
15.1 TO 16.0	0.22 10.9	1.65 19.1	2.01 27.0	1.85 32.6	1.70 36.4	0.85 37.9	0.24 38.1	0.01 38.2

Table 6 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(Contd)
JUNE 1960-74
DIBTINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
16.1 TO 17.0	0.13 5.3	0.69 10.7	1.46 17.2	1.79 23.1	1.49 26.8	1.27 29.0	0.44 29.6	0.05 29.6	
17.1 TO 18.0	0.02 2.2	0.26 5.2	0.91 9.8	1.42 14.9	1.46 19.0	1.24 21.3	0.61 22.2	0.14 22.3	
18.1 TO 19.0	0.0 1.0	0.04 2.2	0.43 4.9	0.94 8.7	1.22 12.3	1.28 14.9	0.72 16.0	0.24 16.2	
19.1 TO 20.0	0.0 0.4	0.01 1.0	0.10 2.1	0.41 4.4	0.81 7.3	0.93 9.7	0.79 11.0	0.25 11.4	0.03 11.4
20.1 TO 21.0	0.0 0.1	0.0 0.4	0.03 1.0	0.11 2.0	0.47 3.9	0.76 5.9	0.78 7.5	0.33 8.0	0.06 8.1
21.1 TO 22.0		0.0 0.1	0.01 0.4	0.06 1.0	0.18 1.9	0.49 3.3	0.60 4.6	0.44 5.3	0.16 5.5
22.1 TO 23.0			0.0 0.1	0.0 0.4	0.07 0.9	0.20 1.6	0.45 2.6	0.39 3.2	0.24 3.5
23.1 TO 24.0				0.0 0.1	0.06 0.4	0.08 0.8	0.20 1.4	0.31 1.8	0.21 2.1
24.1 TO 25.0					0.0 0.1	0.07 0.3	0.13 0.7	0.19 1.0	0.06 1.2
25.1 TO 26.0						0.02 0.1	0.09 0.3	0.14 0.5	0.12 0.6
26.1 TO 27.0							0.05 0.1	0.06 0.2	0.05 0.2
27.1 TO 28.0							0.01 0.0	0.0 0.0	0.02 0.1
28.1 TO 29.0								0.01 0.0	

Table 6(Cont)PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

JUNE 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T(DEG C)	T-9	T-10	T-11
19.1 TO 20.0	0.01 8.1		
20.1 TO 21.0	0.0 5.5		
21.1 TO 22.0			
22.1 TO 23.0	0.04 3.6		
23.1 TO 24.0	0.06 2.2	0.01 2.2	
24.1 TO 25.0	0.06 1.2	0.02 1.2	
25.1 TO 26.0	0.06 0.7	0.01 0.7	
26.1 TO 27.0	0.02 0.2	0.02 0.3	
27.1 TO 28.0	0.0 0.1	0.02 0.1	0.01 0.1
28.1 TO 29.0	0.02 0.0		

Table 7 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
JULY 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB

T (DEG C)

	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
1.1 TO 2.0	0.02 100.0								
2.1 TO 3.0	0.0 100.0								
3.1 TO 4.0	0.05 100.0	0.01 100.0							
4.1 TO 5.0	0.13 99.9	0.02 99.9							
5.1 TO 6.0	0.14 99.7	0.04 99.8							
6.1 TO 7.0	0.17 99.5	0.08 99.6	0.02 99.6						
7.1 TO 8.0	0.44 99.0	0.22 99.3	0.02 99.3						
8.1 TO 9.0	0.56 97.7	0.65 98.6	0.04 98.6						
9.1 TO 10.0	0.82 94.3	1.36 97.1	0.24 97.4						
10.1 TO 11.0	1.67 87.3	2.20 93.5	0.94 94.9	0.03 95.0					
11.1 TO 12.0	1.59 75.4	3.89 85.6	1.79 89.6	0.39 90.1					
12.1 TO 13.0	2.32 61.8	4.20 73.9	2.30 80.1	1.20 82.3	0.10 82.5				
13.1 TO 14.0	1.86 46.5	4.09 59.5	3.01 67.3	1.61 71.3	0.55 72.3	0.04 72.3			
14.1 TO 15.0	1.74 31.4	3.39 44.6	3.06 53.5	1.79 58.4	1.19 60.7	0.29 61.2	0.01 61.2		
15.1 TO 16.0	0.81 19.6	2.79 29.6	2.74 39.5	2.34 45.3	1.41 48.4	0.73 49.6	0.14 49.7		
16.1 TO 17.0	0.31 10.8	1.94 18.8	1.84 26.0	2.32 33.2	1.66 36.7	1.04 38.3	0.35 38.8	0.01 38.8	
17.1 TO 18.0	0.05 5.4	0.89 10.4	1.60 16.5	1.71 21.9	2.28 26.7	1.04 28.6	0.53 29.2	0.10 29.3	0.01 29.3

Table 7 **PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES**
 (Cont) **JULY 1960-74** **BIRMINGHAM AIRPORT**

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
T (DEG C)									
18.1 TO 19.0	0.03 2.4	0.44 5.4	0.99 9.5	1.51 14.0	1.64 17.7	1.34 20.2	0.62 21.0	0.05 21.1	
19.1 TO 20.0	0.0 1.0	0.10 2.4	0.51 4.9	1.08 8.0	1.16 11.0	1.02 13.1	0.79 14.2	0.13 14.4	0.02 14.5
20.1 TO 21.0	0.0 0.3	0.02 1.0	0.17 2.3	0.46 4.3	0.91 6.4	0.99 8.1	0.73 9.2	0.23 9.6	0.02 9.6
21.1 TO 22.0	0.0 0.1	0.0 0.3	0.08 1.0	0.24 2.1	0.47 3.7	0.62 4.8	0.49 5.6	0.25 5.9	0.13 6.1
22.1 TO 23.0		0.01 0.1	0.0 0.3	0.07 0.9	0.25 1.7	0.42 2.9	0.36 3.4	0.22 3.7	0.08 3.8
23.1 TO 24.0			0.01 0.1	0.01 0.3	0.13 0.9	0.27 1.4	0.40 2.1	0.11 2.3	0.08 2.4
24.1 TO 25.0				0.01 0.1	0.02 0.2	0.14 0.7	0.16 1.0	0.18 1.3	0.04 1.4
25.1 TO 26.0				0.0 0.0	0.01 0.1	0.01 0.2	0.12 0.5	0.10 0.7	0.11 0.8
26.1 TO 27.0				0.02 0.0	0.02 0.0	0.02 0.1	0.03 0.2	0.14 0.4	0.0 0.4
27.1 TO 28.0					0.01 0.0			0.03 0.1	0.06 0.2
28.1 TO 29.0									0.02 0.1
29.1 TO 30.0									0.02 0.0

Table 7(Cont)PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

JULY 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB

T(DEG C)	T-9	T-10						DRY-BULB
20.1 TO 21.0	0.01 9.7							(0.00) T 0.1 to 1.5
21.1 TO 22.0	0.03 6.1							0.4 to 1.1
22.1 TO 23.0	0.03 3.8	0.01 3.8						0.2 to 1.4
23.1 TO 24.0								0.2 to 1.2
24.1 TO 25.0								0.1 to 1.0
25.1 TO 26.0	0.02 0.8	0.01 0.8						0.0 to 1.1
26.1 TO 27.0	0.01 0.4							0.0 to 1.0
27.1 TO 28.0	0.03 0.2							0.0 to 1.0
28.1 TO 29.0	0.01 0.1							0.0 to 1.0
29.1 TO 30.0	0.02 0.1							0.0 to 1.0
30.1 TO 31.0	0.01 0.0	0.01 0.0						0.0 to 1.0

Table 8 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
AUGUST 1960-74
BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
2.1 to 3.0	0.01 100.0	0.01 100.0							
3.1 to 4.0	0.08 100.0								
4.1 to 5.0	0.08 99.9	0.04 99.9							
5.1 to 6.0	0.34 99.7	0.08 99.8							
6.1 to 7.0	0.46 99.2	0.18 99.4	0.01 99.4						
7.1 to 8.0	0.69 98.4	0.30 98.7	0.01 98.7						
8.1 to 9.0	1.09 96.9	0.61 97.7	0.03 97.7						
9.1 to 10.0	1.34 93.7	1.48 95.8	0.13 96.0	0.02 96.0					
10.1 to 11.0	1.67 87.4	2.63 92.3	0.50 93.0	0.03 93.0					
11.1 to 12.0	2.43 76.4	3.86 85.8	1.42 88.1	0.13 88.2					
12.1 to 13.0	2.23 60.8	4.75 74.0	2.52 79.5	0.53 80.3	0.01 80.3				
13.1 to 14.0	2.39 45.0	4.83 58.5	3.33 67.0	1.39 70.0	0.22 70.3				
14.1 to 15.0	1.94 31.2	4.03 42.6	2.95 51.3	1.95 56.4	0.74 58.0	0.10 58.1			
15.1 to 16.0	1.08 18.7	3.11 29.3	2.64 36.6	2.23 42.4	1.45 45.6	0.61 46.4	0.01 46.4		
16.1 to 17.0	0.52 9.7	2.21 17.7	2.54 25.1	1.91 29.8	1.74 33.3	0.98 35.1	0.22 35.3		
17.1 to 18.0	0.12 3.6	1.16 9.2	1.66 14.9	1.81 19.8	1.13 22.6	1.20 24.4	0.54 25.2	0.03 25.2	
18.1 to 19.0	0.01 1.2	0.41 3.5	1.13 7.9	1.40 12.0	1.25 15.1	1.01 16.7	0.52 17.3	0.20 17.5	

Table 8 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) AUGUST 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
19.1 to 20.0	0.0 0.4	0.11 1.2	0.39 3.1	1.14 6.4	1.03 9.0	0.97 10.9	0.41 11.5	0.10 11.6	
20.1 to 21.0	0.0 0.1	0.0 0.4	0.03 1.1	0.27 2.6	0.90 4.8	0.80 6.4	0.57 7.2	0.19 7.5	
21.1 to 22.0		0.0 0.1	0.02 0.4	0.07 1.1	0.36 2.3	0.67 3.6	0.55 4.4	0.21 4.7	0.04 4.7
22.1 to 23.0			0.0 0.1	0.02 0.3	0.19 1.0	0.38 1.9	0.30 2.4	0.22 2.7	0.04 2.8
23.1 to 24.0				0.0 0.1	0.04 0.3	0.10 0.8	0.22 1.3	0.18 1.6	0.05 1.6
24.1 to 25.0					0.01 0.1	0.06 0.3	0.13 0.7	0.17 0.9	0.08 1.0
25.1 to 26.0						0.02 0.1	0.06 0.2	0.11 0.5	0.04 0.6
26.1 to 27.0							0.02 0.0	0.04 0.1	0.11 0.3
27.1 to 28.0								0.01 0.0	0.01 0.1
28.1 to 29.0									0.01 0.0
	T-9	T-10	T-11						
23.1 to 24.0	0.02 1.7								
24.1 to 25.0	0.01 1.0	0.03 1.1							
25.1 to 26.0									
26.1 to 27.0	0.05 0.3	0.01 0.3							
27.1 to 28.0	0.02 0.1	0.0 0.1	0.01 0.1						
28.1 to 29.0	0.02 0.0	0.01 0.1	0.0 0.1						
29.1 to 30.0	0.01 0.0	0.01 0.0	0.02 0.0						

Table 9 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
SEPTEMBER, 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-1.9 to -1.0	0.02 100.0								
-0.9 to 0.0	0.03 100.0								
0.1 to 1.0	0.07 100.0								
1.1 to 2.0	0.14 99.9								
2.1 to 3.0	0.35 99.7	0.02 99.7	0.01 99.7						
3.1 to 4.0	0.60 99.3	0.09 99.4							
4.1 to 5.0	0.86 98.5	0.17 98.7							
5.1 to 6.0	1.01 97.2	0.39 97.6							
6.1 to 7.0	1.81 95.4	0.69 96.2	0.04 96.2						
7.1 to 8.0	1.96 91.7	1.35 93.6	0.08 93.7						
8.1 to 9.0	2.36 86.4	1.94 89.7	0.42 90.3	0.01 90.3					
9.1 to 10.0	2.56 78.0	3.19 84.1	0.90 85.4	0.10 85.6					
10.1 to 11.0	2.22 66.7	3.96 75.5	1.46 78.3	0.31 78.8	0.03 78.8				
11.1 to 12.0	3.21 53.5	4.72 64.5	2.49 69.3	0.81 70.7	0.14 70.8				
12.1 to 13.0	2.77 39.4	4.60 50.3	2.89 56.6	1.19 58.9	0.46 59.5	0.02 59.5			
13.1 to 14.0	1.75 25.9	4.00 36.7	2.59 42.9	1.88 46.3	0.71 47.4	0.12 47.5			
14.1 to 15.0	1.19 16.2	2.75 24.1	2.42 30.9	1.69 34.6	1.04 36.1	0.29 36.5	0.02 36.5		

Table 9 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

(contd)

SEPTEMBER 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
15.1 to 16.0	0.60 8.7	2.46 15.0	1.56 20.2	1.74 24.6	1.18 26.5	0.38 27.0	0.06 27.1		
16.1 to 17.0	0.22 3.9	1.42 8.1	1.39 12.0	1.58 15.6	1.48 18.2	0.62 19.0	0.09 19.1	0.01 19.1	
17.1 to 18.0	0.03 1.6	0.63 3.7	0.94 6.5	1.04 8.9	1.03 11.0	0.66 12.1	0.15 12.3	0.01 12.3	
18.1 to 19.0	0.0 0.5	0.16 1.5	0.56 3.1	0.76 4.9	0.59 6.3	0.60 7.3	0.27 7.8	0.01 7.8	
19.1 to 20.0	0.0 0.2	0.01 0.5	0.19 1.4	0.32 2.3	0.43 3.4	0.50 4.2	0.26 4.6	0.17 4.8	0.01 4.9
20.1 to 21.0		0.0 0.2	0.04 0.5	0.21 1.2	0.30 1.8	0.37 2.5	0.20 2.8	0.05 2.9	0.04 3.0
21.1 to 22.0			0.0 0.2	0.05 0.4	0.21 0.9	0.20 1.3	0.19 1.6	0.06 1.7	0.05 1.8
22.1 to 23.0				0.01 0.2	0.07 0.4	0.16 0.7	0.08 0.8	0.09 0.9	0.02 0.9
23.1 to 24.0					0.02 0.1	0.07 0.3	0.07 0.4	0.04 0.5	
24.1 to 25.0						0.03 0.1	0.06 0.2	0.06 0.3	
25.1 to 26.0						0.01 0.0	0.04 0.1	0.02 0.1	
26.1 to 27.0							0.01 0.0	0.02 0.1	0.01 0.1
27.1 to 28.0								0.02 0.0	0.01 0.0
	T-9	T-10							
22.1 to 23.0	0.05 1.0	0.01 1.0							
23.1 to 24.0	0.01 0.5	0.01 0.5							
24.1 to 25.0	0.0 0.3	0.01 0.3							
25.1 to 26.0									
26.1 to 27.0	0.01 0.1								

Table 10 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
OCTOBER 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-4.9 TO -4.0	0.04 100.0								
-3.9 TO -3.0	0.02 100.0								
-2.9 TO -2.0	0.04 99.9								
-1.9 TO -1.0	0.40 99.9	0.02 99.9							
-0.9 TO 0.0	0.54 99.5	0.03 99.5							
0.1 TO 1.0	0.60 98.7	0.22 98.9	0.01 98.9						
1.1 TO 2.0	0.78 97.7	0.28 98.1	0.02 98.1						
2.1 TO 3.0	1.06 96.4	0.39 96.9	0.07 97.0						
3.1 TO 4.0	1.46 94.4	0.57 95.3	0.13 95.5	0.01 95.5					
4.1 TO 5.0	1.94 91.1	1.26 92.9	0.22 93.3	0.05 93.3					
5.1 TO 6.0	2.28 85.9	1.73 89.1	0.33 89.7	0.07 89.8					
6.1 TO 7.0	2.70 78.7	3.03 83.7	0.98 85.1	0.19 85.4	0.01 85.4				
7.1 TO 8.0	2.54 70.0	3.16 76.0	1.29 77.9	0.36 78.4	0.10 78.5	0.02 78.5			
8.1 TO 9.0	2.70 59.6	3.63 67.4	1.95 70.3	0.54 70.9	0.11 71.1				
9.1 TO 10.0	3.82 48.8	4.23 56.9	2.47 61.1	0.82 62.1	0.07 62.1				
10.1 TO 11.0	3.40 37.0	4.25 45.0	1.88 48.8	1.19 50.6	0.13 50.7				
11.1 TO 12.0	2.73 26.3	4.10 33.6	1.88 37.4	1.34 39.3	0.48 39.9	0.01 39.9			

Table 10 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(cont)
October 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
12.1 TO 13.0	1.86 17.2	3.41 23.6	1.85 26.8	1.36 28.7	0.51 29.2	0.08 29.3	0.0 0.00	0.0 0.0	0.0 0.0
13.1 TO 14.0	1.16 9.0	3.01 15.3	1.81 18.3	0.74 19.7	0.37 20.2	0.08 20.3	0.0 0.00	0.0 0.0	0.0 0.0
14.1 TO 15.0	0.54 4.1	2.11 8.6	1.49 11.1	0.77 12.3	0.33 13.0	0.10 13.1	0.0 0.0	0.0 0.0	0.0 0.0
15.1 TO 16.0	0.09 1.4	0.99 3.6	1.42 6.0	0.62 7.0	0.22 7.4	0.25 7.7	0.02 7.7	0.0 0.0	0.0 0.0
16.1 TO 17.0	0.03 0.3	0.42 1.3	0.76 2.5	0.72 3.5	0.33 3.9	0.14 4.1	0.03 4.1	0.0 0.0	0.0 0.0
17.1 TO 18.0		0.06 0.3	0.22 0.9	0.31 1.3	0.22 1.6	0.04 1.6	0.03 1.6	0.01 1.6	0.0 0.0
18.1 TO 19.0			0.05 0.2	0.20 0.6	0.03 0.7	0.04 0.7	0.0 0.7	0.0 0.0	0.0 0.0
19.1 TO 20.0			0.01 0.0	0.04 0.2	0.10 0.3	0.04 0.4	0.0 0.4	0.0 0.0	0.0 0.0
20.1 TO 21.0				0.01 0.0	0.02 0.1	0.05 0.2	0.01 0.2	0.0 0.0	0.0 0.0
21.1 TO 22.0					0.01 0.0	0.03 0.1	0.01 0.1	0.0 0.0	0.0 0.0
22.1 TO 23.0							0.02 0.0	0.0 0.0	0.0 0.0
23.1 TO 24.0						0.01 0.0	0.01 0.0	0.0 0.0	0.0 0.0

Table 11 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
 NOVEMBER 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-6.9 TO -6.0	0.04 100.0	80.0 8.98	72.0 8.28	65.1 7.08	58.1 6.28	51.5 5.58	45.1 4.87	39.1 4.17	33.1 3.47
-5.9 TO -5.0	0.11 100.0	80.0 8.08	72.0 8.08	65.0 7.01	58.1 6.31	50.5 5.21	44.1 4.0	38.1 3.2	32.1 2.4
-4.9 TO -4.0	0.38 99.8	0.06 99.9	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
-3.9 TO -3.0	0.58 99.2	0.17 99.4	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
-2.9 TO -2.0	0.89 98.2	0.35 98.6	0.05 98.7	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
-1.9 TO -1.0	0.97 96.5	0.64 97.3	0.04 97.4	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
-0.9 TO 0.0	1.38 94.1	0.94 95.5	0.19 95.7	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
0.1 TO 1.0	2.06 90.3	1.64 92.7	0.44 93.2	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
1.1 TO 2.0	2.21 85.4	1.98 88.2	0.68 89.0	0.05 89.1	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
2.1 TO 3.0	2.47 79.5	2.64 83.1	0.81 84.0	0.12 84.2	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
3.1 TO 4.0	2.82 72.5	3.18 77.0	0.78 78.0	0.08 78.1	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
4.1 TO 5.0	3.35 62.6	4.76 69.7	1.02 71.0	0.19 71.3	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
5.1 TO 6.0	2.87 49.8	5.79 59.3	1.81 61.6	0.30 61.9	0.03 61.9	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
6.1 TO 7.0	2.67 38.8	5.18 46.9	2.89 50.6	0.42 51.1	0.06 51.2	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
7.1 TO 8.0	2.85 29.4	4.35 36.2	2.19 39.1	0.75 39.9	0.05 40.0	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
8.1 TO 9.0	2.79 21.7	3.35 26.6	1.60 29.0	0.65 29.7	0.08 29.8	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01
9.1 TO 10.0	2.81 13.7	3.36 18.9	1.11 20.5	0.62 21.2	0.06 21.3	0.01 0.01	0.01 0.01	0.01 0.01	0.01 0.01

Table 11 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd)

NOVEMBER 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
10.1 TO 11.0	1.09 7.4	2.44 10.9	1.31 12.7	0.36 13.2	0.16 13.3				
11.1 TO 12.0	0.44 3.8	1.76 6.3	0.81 7.4	0.34 7.9	0.08 8.0				
12.1 TO 13.0	0.22 1.7	1.12 3.3	0.59 4.1	0.31 4.4	0.13 4.5				
13.1 TO 14.0	0.05 0.4	0.63 1.5	0.44 2.0	0.13 2.1	0.02 2.1				
14.1 TO 15.0		0.18 0.3	0.31 0.8	0.07 0.9					
15.1 TO 16.0		0.03 0.0	0.08 0.1	0.15 0.3	0.01 0.3				
16.1 TO 17.0				0.03 0.0	0.04 0.1				

Table PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES

DECEMBER 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-13.9 TO -13.0	0.01 100.0								
-12.9 TO -12.0									
-11.9 TO -11.0	0.02 100.0								
-10.9 TO -10.0	0.02 100.0								
- 9.9 TO - 9.0	0.06 100.0								
- 8.9 TO - 8.0	0.20 99.9	0.03 99.9							
- 7.9 TO - 7.0	0.43 99.6	0.07 99.7							
- 6.9 TO - 6.0	0.59 99.0	0.13 99.2							
- 5.9 TO - 5.0	0.86 98.2	0.24 98.4							
- 4.9 TO - 4.0	0.99 97.0	0.27 97.3	0.02 97.3						
- 3.9 TO - 3.0	1.25 95.4	0.55 96.0	0.04 96.1						
- 2.9 TO - 2.0	1.42 93.0	0.91 94.1	0.13 94.2						
- 1.9 TO -1.0	1.84 89.8	1.42 91.6	0.16 91.8						
- 0.9 TO 0.0	2.74 85.1	2.17 87.9	0.39 88.4	0.01 88.4					
0.1 TO 1.0	2.79 79.0	2.70 82.4	0.61 83.0	0.03 83.1					
1.1 TO 2.0	4.34 72.3	3.22 76.2	0.56 76.9	0.04 76.9					
2.1 TO 3.0	3.92 62.3	4.68 68.0	0.61 68.7	0.12 68.8					

Table 12 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) DECEMBER 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
3.1 to 4.0	3.51 52.6	4.70 58.4	0.93 59.4	0.05 59.5			+00.0 0.001	0.21- of 0.21-	
4.1 to 5.0	2.72 42.7	4.61 49.1	0.97 50.2	0.04 50.3	0.01 50.3		10.0 0.001	0.21- of 0.21-	
5.1 to 6.0	2.27 33.8	4.06 40.0	1.58 41.8	0.14 41.9		+00.0 0.001	+00.0 0.001	0.21- of 0.21-	
6.1 to 7.0	2.40 26.1	3.88 31.5	1.77 33.6	0.22 33.9	0.01 33.9	00.0 0.001	10.0 0.001	0.21- of 0.21-	
7.1 to 8.0	1.87 18.7	3.56 23.7	1.33 25.3	0.30 25.6		+00.0 0.001	10.0 0.001	0.21- of 0.21-	
8.1 to 9.0	1.45 12.1	3.29 16.8	1.20 18.2	0.27 18.5	0.04 18.5		00.0 0.001	0.21- of 0.21-	
9.1 to 10.0	0.77 7.2	2.53 10.6	1.37 12.1	0.17 12.3		+00.0 0.00	00.0 0.00	0.21- of 0.21-	
10.1 to 11.0	0.66 3.6	1.77 6.5	0.61 7.3	0.11 7.4	0.02 7.5	10.0 0.00	20.0 0.00	0.21- of 0.21-	
11.1 to 12.0	0.47 1.6	1.13 3.0	0.96 4.0	0.23 4.3	0.01 4.3	20.0 0.00	00.0 0.00	0.21- of 0.21-	
12.1 to 13.0	0.06 0.1	0.67 1.1	0.25 1.4	0.09 1.5		00.0 0.00	10.0 0.00	0.21- of 0.21-	
13.1 to 14.0		0.07 0.1	0.27 0.4	0.02 0.4		20.0 0.00	10.0 0.00	0.21- of 0.21-	
14.1 to 15.0				0.01 0.0	0.01 0.0	00.0 0.00	00.0 0.00	0.21- of 0.21-	
15.1 to 16.0					0.02 0.0	0.01 0.0	10.0 0.00	0.21- of 0.21-	
16.1 to 17.0								0.01 0.0	0.21- of 0.21-

Table 13 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
ANNUAL 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
-15.9 to -15.0	0.00+ 100.0								
-14.9 to -14.0	0.01 100.0								
-13.9 to -13.0	0.00+ 100.0	0.00+ 100.0							
-12.9 to -12.0	0.01 100.0	0.00+ 100.0							
-11.9 to -11.0	0.01 100.0	0.00+ 100.0							
-10.9 to -10.0	0.03 100.0								
-9.9 to -9.0	0.03 99.9	0.00+ 99.9							
-8.9 to -8.0	0.05 99.9	0.01 99.9							
-7.9 to -7.0	0.09 99.8	0.02 99.9							
-6.9 to -6.0	0.17 99.7	0.03 99.7							
-5.9 to -5.0	0.21 99.5	0.05 99.6							
-4.9 to -4.0	0.28 99.2	0.09 99.3	0.00+ 99.3						
-3.9 to -3.0	0.37 98.7	0.17 98.9	0.00+ 98.9						
-2.9 to -2.0	0.56 98.0	0.32 98.4	0.03 98.4						
-1.9 to -1.0	0.80 96.8	0.57 97.4	0.04 97.5						
-0.9 to 0.0	1.19 94.8	0.88 96.0	0.11 96.1	0.00+ 96.1					
0.1 to 1.0	1.43 91.8	1.37 93.6	0.23 93.9	0.00+ 93.9					

Table 13 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(cont)

ANNUAL 1960-74

BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
1.1 to 2.0	1.56 88.3	1.52 90.3	0.40 90.8	0.02 90.8					
2.1 to 3.0	1.61 84.1	1.89 86.8	0.42 87.3	0.07 87.3	0.00+ 87.3				
3.1 to 4.0	1.77 79.4	2.09 82.5	0.54 83.3	0.07 83.3	0.01 83.4				
4.1 to 5.0	1.78 73.7	2.48 77.7	0.75 78.7	0.15 78.9	0.01 78.9				
5.1 to 6.0	1.63 67.3	2.63 71.9	0.99 73.4	0.21 73.7	0.04 73.7	0.00+			
6.1 to 7.0	1.77 61.2	2.53 65.7	1.31 67.7	0.33 68.1	0.05 68.2	0.00+			
7.1 to 8.0	1.72 54.7	2.55 59.4	1.20 61.4	0.50 62.1	0.11 62.2	0.01 62.2			
8.1 to 9.0	1.57 48.1	2.64 53.0	1.29 55.1	0.53 55.9	0.16 56.1	0.02 56.2	0.0 56.1	0.00+ 56.1	
9.1 to 10.0	1.57 41.1	2.69 46.5	1.32 48.8	0.53 49.6	0.19 49.9	0.03 49.9	0.00+ 49.9		
10.1 to 11.0	1.25 33.8	2.53 39.6	1.29 42.2	0.60 43.2	0.23 43.5	0.05 43.6	0.00+ 43.6		
11.1 to 12.0	1.19 26.9	2.36 32.6	1.47 35.8	0.77 37.2	0.27 37.6	0.06 37.6	0.01 37.6	0.00+ 37.6	
12.1 to 13.0	0.99 20.1	2.11 25.7	1.39 29.0	0.89 30.7	0.38 31.4	0.10 31.5	0.01 31.5	0.00+ 31.5	
13.1 to 14.0	0.71 13.9	1.79 19.1	1.35 22.6	0.87 24.5	0.49 25.4	0.17 25.6	0.02 25.6	0.00+ 25.6	
14.1 to 15.0	0.50 8.8	1.31 13.2	1.20 16.6	0.84 18.7	0.55 19.8	0.25 20.2	0.05 20.2	0.00+ 20.2	
15.1 to 16.0	0.23 5.1	0.94 8.3	0.93 11.4	0.84 13.6	0.61 14.9	0.36 15.4	0.08 15.5	0.01 15.5	0.00+ 15.5
16.1 to 17.0	0.10 2.5	0.56 4.9	0.69 7.2	0.75 9.3	0.64 10.6	0.42 11.3	0.13 11.5	0.02 11.5	0.00+ 11.5
17.1 to 18.0	0.02 1.1	0.25 2.4	0.46 4.2	0.56 5.8	0.56 7.2	0.42 7.9	0.20 8.2	0.04 8.2	0.00+ 8.2

Table 13 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(cont) ANNUAL 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)

DRY-BULB T (DEG C)	T	T-1	T-2	T-3	T-4	T-5	T-6	T-7	T-8
18.1 to 19.0	0.00+ 0.4	0.09 1.1	0.27 2.2	0.42 3.5	0.42 4.5	0.41 5.3	0.22 5.6	0.06 5.7	0.00+ 5.7
19.1 to 20.0	0.0 0.2	0.02 0.4	0.10 1.0	0.26 1.8	0.31 2.7	0.32 3.3	0.22 3.7	0.07 3.8	0.01 3.8
20.1 to 21.0		0.00+ 0.2	0.02 0.4	0.09 0.9	0.23 1.4	0.26 2.0	0.21 2.3	0.08 2.5	0.02 2.5
21.1 to 22.0			0.01 0.2	0.04 0.4	0.10 0.7	0.17 1.1	0.16 1.4	0.09 1.5	0.04 1.6
22.1 to 23.0		0.00+ 0.0	0.0 0.0	0.01 0.2	0.05 0.3	0.10 0.6	0.10 0.8	0.09 0.9	0.03 1.0
23.1 to 24.0			0.00+ 0.0	0.00+ 0.0	0.02 0.1	0.04 0.3	0.08 0.4	0.05 0.5	0.03 0.6
24.1 to 25.0				0.00+ 0.0	0.00+ 0.0	0.03 0.1	0.04 0.2	0.05 0.3	0.02 0.3
25.1 to 26.0					0.00+ 0.0	0.00+ 0.0	0.03 0.1	0.03 0.1	0.02 0.2
26.1 to 27.0				0.00+ 0.0	0.00+ 0.0	0.00+ 0.0	0.01 0.0	0.02 0.1	0.01 0.1
27.1 to 28.0					0.00+ 0.0		0.00+ 0.0	0.00+ 0.0	0.01 0.0
28.1 to 29.0								0.00+ 0.0	0.00+ 0.0
29.1 to 30.0									0.00+ 0.0

Table 13 PERCENTAGE FREQUENCIES OF DRY-BULB AND ASSOCIATED WET-BULB TEMPERATURES
(contd) ANNUAL 1960-74 BIRMINGHAM AIRPORT

ASSOCIATED WET-BULB TEMPERATURE (DEG C)			
DRY-BULB T (DEG C)	T-9	T-10	T-11
17.1 to 18.0	0.00+ 8.2		
18.1 to 19.0			
19.1 to 20.0	0.00+ 3.8		
20.1 to 21.0	0.00+ 2.5		
31.1 to 32.0	0.00+ 1.6	0.00+ 1.6	
32.1 to 33.0	0.01 1.0	0.00+ 1.0	
33.1 to 34.0	0.01 0.6	0.00+ 0.6	
24.1 to 25.0	0.01 0.3	0.01 0.3	
25.1 to 26.0	0.01 0.2	0.00+ 0.2	
26.1 to 27.0	0.01 0.1	0.00+ 0.1	
27.1 to 28.0	0.00+ 0.0	0.00+ 0.0	0.00+ 0.0
28.1 to 29.0	0.00+ 0.0	0.00+ 0.0	
29.1 to 30.0	0.00+ 0.0	0.00+ 0.0	0.00+ 0.0
30.1 to 31.0	0.00+ 0.0	0.00+ 0.0	

Table 14

PERCENTAGE FREQUENCY OF HOURLY DRY-BULB TEMPERATURES BIRMINGHAM AIRPORT 1960-74

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
DRY BULB TEMPERATURE(0.1C)													
-159 TO -150	6.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-149 TO -140	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-139 TO -130	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-129 TO -120	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-119 TO -110	0.1	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-109 TO -100	0.2	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-99 TO -90	0.3	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-89 TO -80	0.4	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0+
-79 TO -70	0.4	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1
-69 TO -60	0.7	0.5	0.4	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.1
-59 TO -50	0.9	0.5	0.4	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.7	0.2
-49 TO -40	1.2	0.8	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0+	0.1	1.1	0.3
-39 TO -30	1.6	1.5	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0+	0.4	1.3	0.4
-29 TO -20	2.2	2.9	1.4	0.4	0.0+	0.0	0.0	0.0	0.0	0.0+	0.7	1.8	0.5
-19 TO -10	4.1	4.6	2.2	0.6	0.1	0.0	0.0	0.0	0.0	0.0+	1.3	2.5	0.9
-9 TO 0	6.2	6.4	3.8	1.2	0.2	0.0+	0.0	0.0	0.0+	0.6	1.6	3.4	1.4
1 TO 10	8.2	9.5	5.5	1.7	0.4	0.0+	0.0	0.0	0.1	0.8	2.5	5.3	2.2
11 TO 20	7.9	8.4	7.2	2.9	0.5	0.0+	0.0	0.0	0.1	1.1	4.1	6.1	3.0
21 TO 30	8.8	9.5	8.4	4.2	0.6	0.1	0.0+	0.0	0.4	1.5	4.9	8.2	3.5
31 TO 40	9.2	10.3	9.0	5.4	1.3	0.4	0.1	0.1	0.7	2.2	6.0	9.3	4.0
41 TO 50	9.4	10.8	9.5	8.2	1.7	0.5	0.2	0.4	1.0	3.5	9.3	8.4	4.5
51 TO 60	9.1	8.8	9.6	9.5	3.4	0.9	0.3	0.6	1.4	4.4	10.8	8.0	5.1
61 TO 70	8.5	7.8	9.0	10.5	5.3	1.4	0.7	0.6	2.5	6.9	11.2	8.3	5.5
71 TO 80	7.4	6.2	8.0	10.5	8.0	2.1	0.7	1.0	3.4	7.5	10.2	7.1	6.0
81 TO 90	5.5	4.8	6.0	9.5	10.8	3.6	1.2	1.7	4.7	8.9	8.5	6.3	6.1
91 TO 100	4.1	3.8	3.5	7.8	11.0	5.4	2.4	3.0	6.7	11.4	8.0	4.8	6.2
101 TO 110	2.4	2.5	2.3	6.2	11.1	7.1	4.8	4.8	8.0	10.8	5.4	3.2	6.3
111 TO 120	1.1	1.1	2.3	4.5	10.2	9.3	7.7	7.8	11.4	10.5	3.4	2.8	6.0
121 TO 130	0.3	0.4	1.1	3.1	8.6	10.9	10.1	10.0	11.9	9.1	2.4	1.1	5.9
131 TO 140	0.0	0.1	0.7	2.0	7.3	10.4	11.2	12.2	11.1	7.2	1.3	0.4	5.4
141 TO 150	0.0	0.0+	0.4	1.1	5.7	9.8	11.5	11.7	9.4	5.4	0.6	0.0+	4.7
151 TO 160	0.0	0.0	0.3	0.5	4.1	8.5	10.9	11.1	8.0	3.6	0.3	0.0+	4.0
161 TO 170	0.0	0.0	0.2	0.3	2.9	7.3	9.5	10.1	6.8	2.5	0.1	0.0+	3.3
171 TO 180	0.0	0.0	0.1	0.3	2.3	6.1	8.2	7.6	4.5	0.9	0.0	0.0	2.5
181 TO 190	0.0	0.0	0.1	0.2	1.7	4.9	6.6	5.9	3.0	0.4	0.0	0.0	1.9
191 TO 200	0.0	0.0	0.1	0.1	1.2	3.3	4.8	4.1	1.9	0.2	0.0	0.0	1.3

BIRMINGHAM AIRPORT 1960-74

PERCENTAGE FREQUENCY OF HOURLY DRY-BULB TEMPERATURES

Table 14 (contd.)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
201 TO 210	0.0	0.0	0.0+	0.0+	0.7	2.6	3.5	2.8	1.2	0.1	0.0	0.0	0.9
211 TO 220	0.0	0.0	0.0+	0.0	0.4	1.9	2.3	1.9	0.8	0.0+	0.0	0.0	0.6
221 TO 230	0.0	0.0	0.0	0.0	0.3	1.4	1.4	1.1	0.5	0.0+	0.0	0.0	0.4
231 TO 240	0.0	0.0	0.0	0.0	0.2	0.9	1.0	0.6	0.2	0.0+	0.0	0.0	0.2
241 TO 250	0.0	0.0	0.0	0.0	0.0+	0.5	0.6	0.5	0.1	0.0	0.0	0.0	0.1
251 TO 260	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.2	0.1	0.0	0.0	0.0	0.1
261 TO 270	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.2	0.0+	0.0	0.0	0.0	0.1
271 TO 280	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0+	0.0+	0.0	0.0	0.0	0.0+
281 TO 290	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0+
291 TO 300	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0+
301 TO 310	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0	0.0	0.0	0.0	0.0	0.0+

$\sigma^+ =$ less than 0.05 percent

Table 15

PERCENTAGE FREQUENCY OF HOURLY WET-BULB TEMPERATURES BIRMINGHAM AIRPORT 1960-74

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
WET BULB TEMPERATURE(0.1C)													
-159 TO	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-149 TO	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-139 TO	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-129 TO	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+
-119 TO	0.1	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-109 TO	0.2	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0+
-99 TO	0.3	0.0+	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0+
-89 TO	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1
-79 TO	0.4	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.1
-69 TO	0.7	0.5	0.4	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.8	0.2
-59 TO	1.1	0.6	0.5	0.0+	0.0	0.0	0.0	0.0	0.0	0.0	0.2	1.2	0.3
-49 TO	1.5	1.2	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0+	0.6	1.7	0.5
-39 TO	1.9	2.1	0.9	0.3	0.0	0.0	0.0	0.0	0.0	0.0	1.0	2.3	0.7
-29 TO	3.2	4.0	2.0	0.5	0.0+	0.0	0.0	0.0	0.0	0.1	1.7	3.2	1.2
-19 TO	5.1	6.3	3.5	0.9	0.1	0.0	0.0	0.0	0.0+	0.4	2.4	4.7	1.9
0	8.1	9.5	6.1	1.7	0.3	0.0+	0.0	0.0	0.0	0.8	3.8	6.1	3.0
1 TO	8.1	10.3	7.2	2.7	0.5	0.0+	0.0	0.0	0.1	1.0	4.9	6.7	3.4
11 TO	8.7	9.4	9.1	4.8	0.6	0.0+	0.0+	0.0+	0.2	1.4	5.9	10.0	4.2
21 TO	10.0	9.3	10.0	6.8	1.1	0.2	0.0+	0.0+	0.4	1.9	7.0	9.7	4.7
31 TO	10.0	11.0	11.3	9.6	2.1	0.5	0.1	0.1	0.8	3.3	9.9	9.9	5.7
41 TO	10.2	10.5	11.6	11.6	3.9	0.7	0.2	0.2	1.3	5.1	12.9	8.9	6.4
51 TO	8.4	7.3	10.1	11.4	6.6	1.3	0.2	0.5	1.8	7.2	10.9	7.7	6.1
61 TO	7.5	6.0	9.3	11.6	10.0	2.5	0.4	0.8	3.7	8.8	9.4	7.3	6.4
71 TO	6.2	4.9	6.9	11.1	13.5	4.6	1.4	1.5	5.3	10.4	7.8	6.7	6.7
81 TO	3.6	3.6	4.9	9.7	14.9	7.8	3.4	3.2	8.4	10.7	7.9	4.8	6.9
91 TO	2.7	2.2	3.1	8.3	13.9	11.2	7.0	6.3	11.3	11.8	6.4	3.6	7.3
101 TO	1.1	0.5	1.2	5.0	10.7	12.4	11.8	11.0	13.2	10.8	3.6	2.1	7.0
111 TO	0.1	0.2	0.7	2.5	8.1	14.1	13.7	15.6	14.1	9.1	2.1	1.4	6.8
121 TO	0.0	0.0+	0.2	0.8	6.1	13.5	15.3	15.8	13.5	7.4	1.3	0.1	6.2
131 TO	0.0	0.0	0.0+	0.3	4.0	11.6	15.1	13.8	9.7	5.7	0.3	0.0	5.1
141 TO	0.0	0.0	0.0+	0.1	1.8	8.7	11.8	12.5	7.5	2.7	0.0+	0.0	3.8
151 TO	0.0	0.0	0.0	0.0+	1.1	5.6	8.8	9.0	4.8	1.1	0.0	0.0	2.6
161 TO	0.0	0.0	0.0	0.0+	0.4	3.1	5.3	6.1	2.4	0.3	0.0	0.0	1.5
171 TO	0.0	0.0	0.0	0.0	0.1	1.2	3.0	2.4	1.1	0.0+	0.0	0.0	0.7
181 TO	0.0	0.0	0.0	0.0	0.0	0.6	1.3	0.9	0.3	0.0+	0.0	0.0	0.3
191 TO	0.0	0.0	0.0	0.0	0.0	0.3	0.8	0.3	0.1	0.0	0.0	0.0	0.1
200	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1	0.0	0.0	0.0	0.0

Table 15 (cont.). PERCENTAGE FREQUENCY OF HOURLY WET-BULB TEMPERATURES BIRMINGHAM AIRPORT 1960-74

WET BULB TEMPERATURE(0.1C)		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
201 TO	210	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0+	0.0	0.0	0.0	0.0+
211 TO	220	0.0	0.0	0.0	0.0	0.0	0.0+	0.1	0.0	0.0	0.0	0.0	0.0	0.0+
221 TO	230	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0	0.0	0.0	0.0	0.0	0.0+
231 TO	240	0.0	0.0	0.0	0.0	0.0	0.0	0.0+	0.0	0.0	0.0	0.0	0.0	0.0+

0+ = less than 0.05 percent.

RELATED CLIMATOLOGICAL MEMORANDA

Percentage frequency of dry-bulb and wet-bulb temperatures:

No.	80	Birmingham Airport 1960-74
	81	London (Heathrow) Airport 1960-74
	82	Manchester Airport 1960-74
	83	Dishforth/Leeming 1960-74
	84	Waddington 1960-74
	85	Mildenhall/Honington 1960-74
	86	Boscombe Down 1960-74
	87	Manston 1961-74
	88	Thorney Island 1960-74
	89	Valley 1960-74
	90	Aberporth 1960-74
	91	Glamorgan Airport (Cardiff) 1960-74
	92	Plymouth (Mount Batten) 1960-74
	93	Lerwick 1960-74
	94	Wick 1960-74
	95	Stornoway 1960-74
	96	Kinloss 1960-74
	97	Edinburgh Airport 1960-74
	98	Tiree 1960-74
	99	Renfrew/Abbotsinch 1960-74
	100	Prestwick 1960-74
	101	Eskdalemuir 1960-74
	102	Aldergrove 1960-74